\underline{C} onsumer \underline{C} onfidence \underline{R} eport

MOUNTAIN LAKES DISTRICT

2021

What is a \underline{C} onsumer \underline{C} onfidence \underline{R} eport?

The Consumer Confidence Report (CCR) details the quality of your drinking water, where it comes from, and where you can get more information. This annual report documents all detected primary and secondary drinking water parameters, and compares them to their respective standards known as Maximum Contaminant Levels (MCLs).





The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.

Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

Organic chemical contaminants, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, can also come from gas stations, urban storm water runoff, and septic systems.

Radioactive contaminants, which can be naturallyoccurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. The US Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same

protection for public health.

What is the source of my drinking water?

Our water comes from 3 different sources.

- 1) Gravel Infiltration Well in the pump house.
- 2) Bedrock Well 100 yards north of the pump house.
- 3) Woodsville Water and Light

Our water sources and system were able to meet our demands and <u>NO BULK WATER WAS BROUGHT</u> <u>IN.</u>

For a disinfectant we treat our sources with Sodium Hypochlorite (Liquid Chlorine).

Why are contaminants in my water? Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Do I need to take special precautions? Some people may be more vulnerable to contaminants in drinking water than the general population. Immu-

no-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline at 1-800-426-4791.

Source Water Assessment Summary

The results of the assessment, prepared on *8-1-2000* are noted below.

001 INF WELL SOURCE TAP. 2 susceptibility factors were rated high. 1 was rated medium and 9 were rated low.

004 BRW 4 SOURCE TAP. 2 susceptibility factors were rated high, 1 was rated medium and 9 were rated low.

Note: Some if this information is over 10 years old and includes information that was current at the time the report was completed. Therefore, some of the ratings might be different if updated to reflect current information. At the present time, DES has no plans to update this data.

The Mountain Lakes District Water Dept. did two separate Microscopic Particulate Analysis (MPA) on the INF WELL SOURCE #001 (Gravel Infiltration Well). The tests were completed in 12-2010 through 4-2011 No issues found in either test.

The complete Assessment Report is available for review at **The Mountain Lakes District.** For more information, call **603 787 6180** or visit the DES Drinking Water Source Assessment website at http://des.nh.gov/organization/divisions/water/dwgb/dwspp/dwsap.htm.

How can I get involved?

The Mountain Lakes District Water Committee meets monthly at the District office (Please call for times and schedule).

For more information about your drinking water please contact The Mountain Lakes District

Mountain Lakes District

75 White Mountain Road

Woodsville NH, 03785

Office: (603) 787 6180

Fax: (603) 787 2154

E-mail: <u>mldadmin@mountainlakesnh.com</u>

mtnlakeswater@yahoo.com

Web: <u>www.mountainlakesnh.com</u>

District Commissioners:

Robert F Long

Michael A Roberts

Mark Johanson

District Office Administrator: Kristi Garofalo,
Water System Operator: Donald Drew

Violations and Other information: We are very pleased to report that all of our water sources are safe to drink. We had a Total Coliform hit in our October 2020 test. We did 10 additional test and found no issue. We have met state and Federal requirements and had no violations on our last Sanitary Survey. We did not exceed any of the MCL's. We met our 90% Lead And Copper test in the 4th Q of 2019. All test results and follow up information will be on file and all water customers will be notified if further action is required. We have and continue to meet all testing requirements and have no violations to report. All monthly and quarterly test results are

available at the Mountain Lakes District office. These test may vary from year to year depending on results, water sources, rule change and compliance schedules.

Definitions

Ambient Groundwater Quality Standard or AGQS:

The maximum concentration levels for contaminants in groundwater that are established under RSA 485-C, the Groundwater Protection Act.

Action Level or **AL:** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level or **MCL**: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal or **MCLG:** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level or MRDL:

The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal or MRDLG: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Treatment Technique or **TT:** A required process intended to reduce the level of a contaminant in drinking water.

Turbidity: A measure of the cloudiness of the water. It is monitored by surface water systems because it is a good indicator of water quality and thus helps measure the effectiveness of the treatment process. High turbidity can hinder the effectiveness of disinfectants.

Abbreviations

BDL: Below Detection Limit

mg/L: milligrams per Liter

NA: Not Applicable

ND: Not Detectable at testing limits NTU: Nephelometric Turbidity Unit

pCi/L: picoCurie per Liter ppb: parts per billion

ppm: parts per million

RAA: Running Annual Average TTHM: Total Trihalomethanes

UCMR: Unregulated Contaminant Monitoring Rule

ug/L: micrograms per Liter

MCL: Maximum Contaminant Level

AL: Action Level

System information:

The Mountain Lakes District Water Department and The Water Committee take every effort to ensure a safe drinking water. The District has completed a Boat Washing area and has posted informational signs around the lakes. We set up an information display with tips, projects and goals at our Annual Meeting. We do ongoing leak detection with Granite State Rural Water and other private professionals, We send reminders to use eco. friendly cleaners, along with continuing our efforts with the annual Volunteer Lake Assessment Program (VLAP) (scheduled for August 2021). We will be monitoring the two main beaches for E Coli during the summer months. We maintain an open door policy with all of our customers and residents. The emergency/informational e-mail tree has been very helpful in getting urgent messages to the residents when needed. We would be happy to go over our current projects and future plans for ongoing source development and improvements. We are continuing efforts for a new well source. We have found this to be a very long and tedious process. Some water main replacement on Bear Road is scheduled for the spring of 2020. Please refer to the monthly water system report or check updates on The Mountain Lakes District web site

Web: <u>www.mountainlakesnh.com</u>